Pinal County Environmental Health Services
As Governed by
A.A.C. Title 9, Chapter 8, Article 8
P.O. Box 2517, 31 N. Pinal St., Bldg F
Florence, AZ 85232
(520) 866-6864
Fax (520) 866-6007

PINAL • COUNTY
wide open opportunity

PUBLIC AND SEMI PUBLIC BATHING PLACE

INSPECTION REPORT

Facility Name:	Marana Aerospace	Classification:	Semi
Address:	24641 E Pinal Air Park	City:	Marana
Owner/Operator:	(Roxanne)	Phone #:	
Permit #:	12-006	Type of Inspection:	Routine

Based on an inspection this day, the items marked below may identify violations in operation of facilities which must be corrected by the next inspection or by the time specified by the health authority, failure to comply with this notice may result in immediate suspension of your permit. An opportunity for an appeal will be provided if a written request is filed with the health authority within the period of time established in this notice for correction of violations.

Y = yes N = no N/A = not applicable N/O = not observed

TYPE OF BATHING PLACE:	Pool	P
DISINFECTION LEVELS	**READINGS**	**Compliance Status**
1 **If chlorine is used as disinfectant** (Pool) R9-8-803 D.1 (Spa) R9-8-803 E.3.a	5++	N
2 **If bromine is used as a disinfectant** (Pool) R9-8-803 D.2 (Spa) R9-8-803 E.3.b	N/A	
OPERATING PROCEDURES & STANDARDS		
3 **pH is between 7.2 and 7.8** R9-8-803 A.2.b	7.6	Y
4 **Total alkalinity is between 60 and 100 ppm.** R9-8-803 A.2.c	80	Y
5 **Cyanuric acid level does not exceed 150 ppm.** R9-8-803 C	N/O	
6 **Only potable water is used for filling.** R9-8-803 A.1		Y
7 **Main drain clearly visible from the deck.** R9-8-803 A.2.d		Y
8 **Surface of the water is free from scum and floating debris.** R9-8-803 A.3		Y
9 **Bottom and sides free of sediment, dirt, slime and algae.** R9-8-803 A.4		Y
10 **Chemical disinfection level, pH, total alkalinity, and temperature of water tested at least once daily.** R9-8-803 A.5		N/O
11 **Daily operating log is maintained for 12 months and available to regulatory authority or member of the public upon request.** R9-803 A.6		N/O
12 **Dry or liquid disinfectant is not being directly added to bathing place for routine disinfection.** R9-8-803 B.3		N/O

TYPE OF BATHING PLACE:	P
FACILITY SANITATION	**Compliance Status**
13 **If present, restroom facility is maintained in clean condition.** R9-8-807 A	Y
14 **Dispenser with powdered or liquid soap is located at each sink in the sanitary facility.** R9-8-807 B	Y
WATER CIRCULATION REQUIREMENTS	
15 **Water circulation complies with requirements** R9-8-804 A.1	Y
16 **Flow meter is present** R9-8-804 A.2.a	N/O
17 **Vacuum cleaning system is present.** R9-8-804 A.2.b	N/O
POSTING REQUIREMENTS	
18 **Operator has sign posted within 50 feet of bathing place with proper instructions to individuals using facility.** R9-8-806	Y
SEWAGE DISPOSAL, FILTER BACKWASH & WASTED WATER	
19 **Sewage, filter backwash from bathing place is properly disposed.** R9-8-809	N/O

A copy of the Arizona Administrative Code R9-8-801 through R9-8-813 is available at:

www.azsos.gov/public_services/Title_09/9-08.htm#Article_8

For information regarding Fecal Contamination Response Procedures see R9-8-810

Comments:
Please provide shepherds crook & ring bouy w rope.
Cl is too high in pool. Please keep pool closed until Cl conc is 1-3 ppm.

ALL VIOLATIONS ARE TO BE CORRECTED BY: _____

REPORT RECEIVED BY: Roxanne McGlothen 11/4/14

INSPECTED BY: [signature] DATE/TIME: 11/4/14; 12p

Revised 4/22/2009

PINAL • COUNTY
wide open opportunity

PINAL COUNTY ENVIRONMENTAL HEALTH SERVICES

NOTICE OF INSPECTION RIGHTS

Facility Inspected: Marana Aerospace Pool Permit No. 12-006
Address: 24641 E Pinal Air Park City: Marana Zip: _____
Inspector: J. Avolan Accompanied by: _____

1. This inspection is conducted under the authority of Arizona Revised Statutes (A.R.S.) Title 36, Chapter 1, Article 2, § 36-136(D), Arizona Department of Health Services/Pinal County Delegation Agreement No. AGR2007-108, and Arizona Administrative Code (A.A.C.) Title 9, Chapter 8, Article 1 (Food and Drink), Title 9, Chapter 8, Article 2 (Bottled Water), Title 9, Chapter 8, Article 3 (Public Toilet Facilities), Title 9, Chapter 8, Article 4 (Children's Camps), Title 9, Chapter 8, Article 5 (Trailer Coach Parks), Title 9, Chapter 8, Article 6 (Camp Grounds), Title 9, Chapter 8, Article 7 (Public Schools), Title 9, Chapter 8, Article 8 (Public and Semipublic Swimming Pools and Bathing Places), and Title 9, Chapter 8, Article 13 (Hotels, Motels, and Tourist Courts).

2. The purpose of this inspection is to assess compliance of your establishment/facility with the above-listed administrative rules and regulations as they pertain to the issuance of a license or compliance with licensure requirements.

3. Applicable fees associated with this inspection: ☑ None ☐ Fee Amount $_____

4. An authorized on-site representative of the regulated person may accompany the County inspector on the premises, except during confidential interviews.

5. You have the right to have:
   - Copies of any original documents taken by the county during the inspection if the County is permitted by law to take the original documents;
   - A split of any samples taken during the inspection if the split of any samples would not prohibit an analysis from being conducted or render an analysis inconclusive; and
   - Copies of any analysis performed on samples taken during the inspection

6. Each person who has a conversation with the County inspector during the inspection that is tape recorded will be informed that the conversation is being tape recorded.

7. Each person interviewed will be informed that statements made by the person may be included in the inspection report.

8. Your due process rights relating to an appeal of a final decision of the County based on the results of the inspection are found at A.R.S. §§ 41-1061 to 41-1066. Your rights relating to an appeal of a final County decision are found in A.R.S. § 12-901, *et seq.* A county decision pursuant to A.R.S. § 11-1603 E and F is not an appealable county action.

9. For questions regarding the inspection or to get further information about due process rights of a regulated person relating to an appeal of a final decision based on the results of the inspection, you may contact: Environmental Health Programs Manager, 971 N. Jason Lopez Circle, PO Box 2945, Florence, Arizona 85132, Phone: (866) 960-0633, FAX: (520) 866-7066 or contact the inspector at the number provided on the inspection report.

Upon entry to the premises for this inspection, the inspector(s) presented photo identification and reviewed with me the above Notice of Inspection Rights. I have read the disclosures and am notified of my inspection and due process rights as listed. I understand that while I have the right to decline to sign this form, the Pinal County Environmental Health Services inspector(s) may proceed with the inspection.

Printed name of regulated person or on-site representative of the regulated person

Roxanne McPlaten 11/4/14
Signature of regulated person or on-site representative of the regulated person Date of Inspection

☐ Regulated person or on-site representative refused to sign this form
☐ Regulated person or on-site representative is not present

11/4/14
PCEHS Inspector(s) Signature Date of Inspection

☑ Copy left with the regulated person or on-site representative of the regulated person
☐ Copy faxed, mailed, emailed to the regulated person or on-site representative of the regulated person _____

Roxanne - 520-343-3188 (mobile and)

Pinal County Environmental Health Services
As Governed by
A.A.C. Title 9, Chapter 8, Article 8
P.O. Box 2517, 31 N. Pinal St., Bldg F
Florence, AZ 85232
(520) 866-6864
Fax (520) 866-6007

PINAL • COUNTY
wide open opportunity

PUBLIC AND SEMI PUBLIC BATHING PLACE

INSPECTION REPORT

Facility Name:	Marana Aerospace Sch	Classification:	Semi
Address:	21641 E Pinal Air Park	City:	Marana
Owner/Operator:		Phone #:	
Permit #:	12-006	Type of Inspection:	Routine

Based on an inspection this day, the items marked below may identify violations in operation of facilities which must be corrected by the next inspection or by the time specified by the health authority, failure to comply with this notice may result in immediate suspension of your permit. An opportunity for an appeal will be provided if a written request is filed with the health authority within the period of time established in this notice for correction of violations.

Y = yes N = no N/A = not applicable N/O = not observed

	TYPE OF BATHING PLACE:	P		P	
	DISINFECTION LEVELS	**READINGS**		**Compliance Status**	
1	**If chlorine is used as disinfectant** (Pool) R9-8-803 D.1 (Spa) R9-8-803 E.3.a	3.0		Y	
2	**If bromine is used as a disinfectant** (Pool) R9-8-803 D.2 (Spa) R9-8-803 E.3.b	N/A			
	OPERATING PROCEDURES & STANDARDS				
3	**pH is between 7.2 and 7.8** R9-8-803 A.2.b	7.6		Y	
4	**Total alkalinity is between 60 and 100 ppm.** R9-8-803 A.2.c	100		Y	
5	**Cyanuric acid level does not exceed 150 ppm.** R9-8-803 C	N/O			
6	**Only potable water is used for filling.** R9-8-803 A.1			Y	
7	**Main drain clearly visible from the deck.** R9-8-803 A.2.d			Y	
8	**Surface of the water is free from scum and floating debris.** R9-8-803 A.3			Y	
9	**Bottom and sides free of sediment, dirt, slime and algae.** R9-8-803 A.4			Y	
10	**Chemical disinfection level, pH, total alkalinity, and temperature of water tested at least once daily.** R9-8-803 A.5			N/O	
11	**Daily operating log is maintained for 12 months and available to regulatory authority or member of the public upon request.** R9-803 A.6			N/O	
12	**Dry or liquid disinfectant is not being directly added to bathing place for routine disinfection.** R9-8-803 B.3			N/O	

	TYPE OF BATHING PLACE:	P	
	FACILITY SANITATION	**Compliance Status**	
13	**If present, restroom facility is maintained in clean condition.** R9-8-807 A	Y	
14	**Dispenser with powdered or liquid soap is located at each sink in the sanitary facility.** R9-8-807 B	Y	
	WATER CIRCULATION REQUIREMENTS		
15	**Water circulation complies with requirements** R9-8-804 A.1	Y	
16	**Flow meter is present** R9-8-804 A.2.a	N/O	
17	**Vacuum cleaning system is present.** R9-8-804 A.2.b	N/O	
	POSTING REQUIREMENTS		
18	**Operator has sign posted within 50 feet of bathing place with proper instructions to individuals using facility.** R9-8-806	Y	
	SEWAGE DISPOSAL, FILTER BACKWASH & WASTED WATER		
19	**Sewage, filter backwash from bathing place is properly disposed.** R9-8-809	N/O	

A copy of the Arizona Administrative Code R9-8-801 through R9-8-813 is available at:

www.azsos.gov/public_services/Title_09/9-08.htm#Article_8

For information regarding Fecal Contamination Response Procedures see R9-8-810

Comments:

ALL VIOLATIONS ARE TO BE CORRECTED BY: _____

REPORT RECEIVED BY: Copy @ office

INSPECTED BY: [signature] DATE/TIME: 8/29/14

Revised 4/22/2009

PINAL • COUNTY
wide open opportunity

PINAL COUNTY ENVIRONMENTAL HEALTH SERVICES

NOTICE OF INSPECTION RIGHTS

Facility Inspected: Marana Aerospace Soln Pool Permit No. 12-006
Address: 24641 E Rinal Air Pk City: Marana Zip: _____
Inspector: J Abbas Accompanied by: _____

1. This inspection is conducted under the authority of Arizona Revised Statutes (A.R.S.) Title 36, Chapter 1, Article 2, § 36-136(D), Arizona Department of Health Services/Pinal County Delegation Agreement No. AGR2007-108, and Arizona Administrative Code (A.A.C.) Title 9, Chapter 8, Article 1 (Food and Drink), Title 9, Chapter 8, Article 2 (Bottled Water), Title 9, Chapter 8, Article 3 (Public Toilet Facilities), Title 9, Chapter 8, Article 4 (Children's Camps), Title 9, Chapter 8, Article 5 (Trailer Coach Parks), Title 9, Chapter 8, Article 6 (Camp Grounds), Title 9, Chapter 8, Article 7 (Public Schools), Title 9, Chapter 8, Article 8 (Public and Semipublic Swimming Pools and Bathing Places), and Title 9, Chapter 8, Article 13 (Hotels, Motels, and Tourist Courts).

2. The purpose of this inspection is to assess compliance of your establishment/facility with the above-listed administrative rules and regulations as they pertain to the issuance of a license or compliance with licensure requirements.

3. Applicable fees associated with this inspection: ☑ None ☐ Fee Amount $_____

4. An authorized on-site representative of the regulated person may accompany the County inspector on the premises, except during confidential interviews.

5. You have the right to have:
   - Copies of any original documents taken by the county during the inspection if the County is permitted by law to take the original documents;
   - A split of any samples taken during the inspection if the split of any samples would not prohibit an analysis from being conducted or render an analysis inconclusive; and
   - Copies of any analysis performed on samples taken during the inspection

6. Each person who has a conversation with the County inspector during the inspection that is tape recorded will be informed that the conversation is being tape recorded.

7. Each person interviewed will be informed that statements made by the person may be included in the inspection report.

8. Your due process rights relating to an appeal of a final decision of the County based on the results of the inspection are found at A.R.S. §§ 41-1061 to 41-1066. Your rights relating to an appeal of a final County decision are found in A.R.S. § 12-901, *et seq*. A county decision pursuant to A.R.S. § 11-1603 E and F is not an appealable county action.

9. For questions regarding the inspection or to get further information about due process rights of a regulated person relating to an appeal of a final decision based on the results of the inspection, you may contact: Environmental Health Programs Manager, 971 N. Jason Lopez Circle, PO Box 2945, Florence, Arizona 85132, Phone: (866) 960-0633, FAX: (520) 866-7066 or contact the inspector at the number provided on the inspection report.

Upon entry to the premises for this inspection, the inspector(s) presented photo identification and reviewed with me the above Notice of Inspection Rights. I have read the disclosures and am notified of my inspection and due process rights as listed. I understand that while I have the right to decline to sign this form, the Pinal County Environmental Health Services inspector(s) may proceed with the inspection.

_____
Printed name of regulated person or on-site representative of the regulated person

_____
Signature of regulated person or on-site representative of the regulated person Date of Inspection

☐ Regulated person or on-site representative refused to sign this form
☑ Regulated person or on-site representative is not present

[signature] 8/29/14
PCEHS Inspector(s) Signature Date of Inspection

☐ Copy left with the regulated person or on-site representative of the regulated person
☐ Copy faxed, mailed, emailed to the regulated person or on-site representative of the regulated person Office

Pinal County Environmental Health Services
As Governed by
A.A.C. Title 9, Chapter 8, Article 8
P.O. Box 2517, 31 N. Pinal St., Bldg F
Florence, AZ 85232
(520) 866-6864
Fax (520) 866-6007

PINAL • COUNTY
wide open opportunity

PUBLIC AND SEMI PUBLIC BATHING PLACE

INSPECTION REPORT

Facility Name:	Marana Aerospace	Classification:	Semi
Address:	24641 E Pinal Air park	City:	Marana
Owner/Operator:		Phone #:	
Permit #:	12-006	Type of Inspection:	Routine

Based on an inspection this day, the items marked below may identify violations in operation of facilities which must be corrected by the next inspection or by the time specified by the health authority, failure to comply with this notice may result in immediate suspension of your permit. An opportunity for an appeal will be provided if a written request is filed with the health authority within the period of time established in this notice for correction of violations.

Y = yes N = no N/A = not applicable N/O = not observed

TYPE OF BATHING PLACE: Pool P

	DISINFECTION LEVELS	READINGS	Compliance Status
1	**If chlorine is used as disinfectant** (Pool) R9-8-803 D.1 (Spa) R9-8-803 E.3.a	3.0	Y
2	**If bromine is used as a disinfectant** (Pool) R9-8-803 D.2 (Spa) R9-8-803 E.3.b	N/A	
	OPERATING PROCEDURES & STANDARDS		
3	**pH is between 7.2 and 7.8** R9-8-803 A.2.b	7.4	Y
4	**Total alkalinity is between 60 and 100 ppm.** R9-8-803 A.2.c	100	Y
5	**Cyanuric acid level does not exceed 150 ppm.** R9-8-803 C	N/O	
6	**Only potable water is used for filling.** R9-8-803 A.1		Y
7	**Main drain clearly visible from the deck.** R9-8-803 A.2.d		Y
8	**Surface of the water is free from scum and floating debris.** R9-8-803 A.3		Y
9	**Bottom and sides free of sediment, dirt, slime and algae.** R9-8-803 A.4		Y
10	**Chemical disinfection level, pH, total alkalinity, and temperature of water tested at least once daily.** R9-8-803 A.5		N/O
11	**Daily operating log is maintained for 12 months and available to regulatory authority or member of the public upon request.** R9-803 A.6		N/O
12	**Dry or liquid disinfectant is not being directly added to bathing place for routine disinfection.** R9-8-803 B.3		N/O

TYPE OF BATHING PLACE: P.

	FACILITY SANITATION	Compliance Status
13	**If present, restroom facility is maintained in clean condition.** R9-8-807 A	Y
14	**Dispenser with powdered or liquid soap is located at each sink in the sanitary facility.** R9-8-807 B	Y
	WATER CIRCULATION REQUIREMENTS	
15	**Water circulation complies with requirements** R9-8-804 A.1	Y
16	**Flow meter is present** R9-8-804 A.2.a	N/O
17	**Vacuum cleaning system is present.** R9-8-804 A.2.b	N/O
	POSTING REQUIREMENTS	
18	**Operator has sign posted within 50 feet of bathing place with proper instructions to individuals using facility.** R9-8-806	Y
	SEWAGE DISPOSAL, FILTER BACKWASH & WASTED WATER	
19	**Sewage, filter backwash from bathing place is properly disposed.** R9-8-809	N/O

A copy of the Arizona Administrative Code R9-8-801 through R9-8-813 is available at:

www.azsos.gov/public_services/Title_09/9-08.htm#Article_8

For information regarding Fecal Contamination Response Procedures see R9-8-810

Comments:

ALL VIOLATIONS ARE TO BE CORRECTED BY: _____

REPORT RECEIVED BY: Copy @ pool

INSPECTED BY: [signature] DATE/TIME: 6/10/14 / 12pm

Revised 4/22/2009

PINAL • COUNTY
wide open opportunity

PINAL COUNTY ENVIRONMENTAL HEALTH SERVICES

NOTICE OF INSPECTION RIGHTS

Facility Inspected: Pinal Air Park Permit No. 09-1078
Address: 24641 E Pinal Air Park City: Marana Zip:
Inspector: J. Ablan Accompanied by:

1. This inspection is conducted under the authority of Arizona Revised Statutes (A.R.S.) Title 36, Chapter 1, Article 2, § 36-136(D), Arizona Department of Health Services/Pinal County Delegation Agreement No. AGR2007-108, and Arizona Administrative Code (A.A.C.) Title 9, Chapter 8, Article 1 (Food and Drink), Title 9, Chapter 8, Article 2 (Bottled Water), Title 9, Chapter 8, Article 3 (Public Toilet Facilities), Title 9, Chapter 8, Article 4 (Children's Camps), Title 9, Chapter 8, Article 5 (Trailer Coach Parks), Title 9, Chapter 8, Article 6 (Camp Grounds), Title 9, Chapter 8, Article 7 (Public Schools), Title 9, Chapter 8, Article 8 (Public and Semipublic Swimming Pools and Bathing Places), and Title 9, Chapter 8, Article 13 (Hotels, Motels, and Tourist Courts).

2. The purpose of this inspection is to assess compliance of your establishment/facility with the above-listed administrative rules and regulations as they pertain to the issuance of a license or compliance with licensure requirements.

3. Applicable fees associated with this inspection: ☑ None ☐ Fee Amount $_____

4. An authorized on-site representative of the regulated person may accompany the County inspector on the premises, except during confidential interviews.

5. You have the right to have:
   - Copies of any original documents taken by the county during the inspection if the County is permitted by law to take the original documents;
   - A split of any samples taken during the inspection if the split of any samples would not prohibit an analysis from being conducted or render an analysis inconclusive; and
   - Copies of any analysis performed on samples taken during the inspection

6. Each person who has a conversation with the County inspector during the inspection that is tape recorded will be informed that the conversation is being tape recorded.

7. Each person interviewed will be informed that statements made by the person may be included in the inspection report.

8. Your due process rights relating to an appeal of a final decision of the County based on the results of the inspection are found at A.R.S. §§ 41-1061 to 41-1066. Your rights relating to an appeal of a final County decision are found in A.R.S. § 12-901, *et seq.* A county decision pursuant to A.R.S. § 11-1603 E and F is not an appealable county action.

9. For questions regarding the inspection or to get further information about due process rights of a regulated person relating to an appeal of a final decision based on the results of the inspection, you may contact: Environmental Health Programs Manager, 971 N. Jason Lopez Circle, PO Box 2945, Florence, Arizona 85132, Phone: (866) 960-0633, FAX: (520) 866-7066 or contact the inspector at the number provided on the inspection report.

Upon entry to the premises for this inspection, the inspector(s) presented photo identification and reviewed with me the above Notice of Inspection Rights. I have read the disclosures and am notified of my inspection and due process rights as listed. I understand that while I have the right to decline to sign this form, the Pinal County Environmental Health Services inspector(s) may proceed with the inspection.

LARA N. FISK
Printed name of regulated person or on-site representative of the regulated person

Signature of regulated person or on-site representative of the regulated person — Date of Inspection: 6/10/14

☐ Regulated person or on-site representative refused to sign this form
☐ Regulated person or on-site representative is not present

PCEHS Inspector(s) Signature — Date of Inspection: 6/10/14

☑ Copy left with the regulated person or on-site representative of the regulated person
☐ Copy faxed, mailed, emailed to the regulated person or on-site representative of the regulated person _____

Pinal County Environmental Health Services
As Governed by
A.A.C. Title 9, Chapter 8, Article 7
PO Box 2945, 971 N.Jason Lopez Circle, Bldg.D
Florence, AZ 85132
Phone: (866) 287-0209
Fax: (520) 866-7066

PINAL • COUNTY
Wide open opportunity

PUBLIC AND SEMI PUBLIC BATHING PLACE

INSPECTION REPORT

Facility Name:	MARANA AEROSPACE SOLUTIONS	Classification:	Semi-Public
Address:	24641 E PINAL AIR PARK RD	City:	MARANA
Owner:		Operator:	
Permit #:	BP-12-006	Phone:	
Type of Inspection:	Follow Up		

Based on an inspection this day, the items marked below may identify violations in operation of facilities which must be corrected by the next inspection or by the tim specified by the health authority, failure to comply with this notice may result in immediate suspension of your permit. An opportunity for an appeal will be provided if written request is filed with the health authority within the period of time established in this notice for correction of violations.

Y = Yes N = No N/O = Not Observed N/A = Not Applicable

	TYPE OF BATHING PLACE:	Pool	Spa	Pool	Spa
	DISINFECTION LEVELS	READINGS		Compliance Status	
1	If chlorine is used as disinfectant (Pool) R9-8-803 D.1 (Spa)R9-8-803 E.3.a	3.0 ppm		Y	
2	If bromine is used as disinfectant (Pool) R9-8-803 D.2 (Spa)R9-8-803 E.3.b	ppm		N/A	
	OPERATING PROCEDURES & STANDINGS				
3	pH is between 7.2 and 7.8 R9-8-803 A.2.b.a	7.6 ppm		Y	
4	Total alkalinity is 60 and 100 ppm R9-8-803 A.2.c.b	150 ppm		N	
5	Cyanuric acid level does not exceed 150 ppm. R9-8-803 C	30 ppm		Y	
6	Only Potable water is used for filling R9-8-803 A.1a			Y	
7	Main drain clearly visible from the deck. R9-8-803 A.2.d			Y	
8	Surface of the water is free from scum and floating debris R9-8-803 A.3			Y	
9	Bottom and sides free of sediment, dirt, slime and algae. R9-8-803 A.4			N	
10	Chemical disinfection level, pH, total alkalinity, and temperature of water tested at lease once daily. R9-8-803 A.5			Y	
11	Daily operating log is maintained for 12 months and available to regulatory authority or member of the public upon request. R9-8-803 A.6			Y	
12	Dry or liquid disinfectant is not being directly added to bathing place for routine disinfection. R9-8-803 B.3			Y	

	TYPE OF BATHING PLACE:	Pool	Sp
	FACILITY SANITATION	Compliance Status	
13	If present, restroom facility is maintained in clean condition R9-8-807 A	Y	
14	Dispenser with powdered or liquid soap is located at each sink in the sanitary facility. R9-8-807 B	Y	
	WATER CIRCULATION REQUIREMENTS		
15	Water Circulation complies with requirements R9-8-804 A.1	Y	
16	Flow meter is present R9-8-804 A.2.a	N	
17	Vacuum cleaning system is present. R9-8-804 A.2.b	Y	
	POSTING REQUIREMENTS		
18	Operator has sign posted within 50 feet of bathing place with proper instructions to individuals using facilities R9-8-806	Y	
	SEWAGE DISPOSAL, FILTER BACKWASH AND WASTE WATER		
19	Sewage, filter backwash from bathing place is properly disposed R9-8-809	Y	

A copy of the Arizona Administrative Code R9-8-801 through R9-8-813 is available at: www.azsos.gov/public_service/Title_09/9-08.htm#Article_8

For information regarding Fecal Contamination Response Procedures see R9 810

Comments:

Total alkalinity should be 60-100 ppm. Bottom of pool is to be vacuumed tomorrow. Flow meter is needed for pump system. Back flow preventer is needed for hose used to fill pool.

ALL VIOLATIONS ARE TO BE CORRECTED BY: next routine inspection

REPORT RECEIVED BY:

INSPECTED BY: Doug Walker **DATE/TIME:** 7/23/2013 4:06:11 PM

Pinal County Environmental Health Services
As Governed by
A.A.C. Title 9, Chapter 8, Article 8
P.O. Box 2517, 31 N. Pinal St., Bldg F
Florence, AZ 85232
(520) 866-6864
Fax (520) 866-6007

PINAL • COUNTY
wide open opportunity

PUBLIC AND SEMI PUBLIC BATHING PLACE

INSPECTION REPORT

Facility Name:	Marana aerospace Solutions	Classification:	Semi public
Address:	~~Marana~~ Pinal air park Rd.	City:	Marana
Owner/Operator:	24641	Phone #:	
Permit #:		Type of Inspection:	Routine

Based on an inspection this day, the items marked below may identify violations in operation of facilities which must be corrected by the next inspection or by the time specified by the health authority, failure to comply with this notice may result in immediate suspension of your permit. An opportunity for an appeal will be provided if a written request is filed with the health authority within the period of time established in this notice for correction of violations.

Y = yes N = no N/A = not applicable N/O = not observed

	TYPE OF BATHING PLACE:	P		P	
	DISINFECTION LEVELS	**READINGS**		**Compliance Status**	
1	**If chlorine is used as disinfectant** (Pool) R9-8-803 D.1 (Spa) R9-8-803 E.3.a	3.0		Y	
2	**If bromine is used as a disinfectant** (Pool) R9-8-803 D.2 (Spa) R9-8-803 E.3.b				
	OPERATING PROCEDURES & STANDARDS				
3	**pH is between 7.2 and 7.8** R9-8-803 A.2.b	7.6		Y	
4	**Total alkalinity is between 60 and 100 ppm.** R9-8-803 A.2.c	150		N	
5	**Cyanuric acid level does not exceed 150 ppm.** R9-8-803 C	30		Y	
6	**Only potable water is used for filling.** R9-8-803 A.1			Y	
7	**Main drain clearly visible from the deck.** R9-8-803 A.2.d			Y	
8	**Surface of the water is free from scum and floating debris.** R9-8-803 A.3			Y	
9	**Bottom and sides free of sediment, dirt, slime and algae.** R9-8-803 A.4			N	
10	**Chemical disinfection level, pH, total alkalinity, and temperature of water tested at least once daily.** R9-8-803 A.5			Y	
11	**Daily operating log is maintained for 12 months and available to regulatory authority or member of the public upon request.** R9-803 A.6			Y	
12	**Dry or liquid disinfectant is not being directly added to bathing place for routine disinfection.** R9-8-803 B.3			Y	

	TYPE OF BATHING PLACE:	P	
	FACILITY SANITATION	**Compliance Status**	
13	**If present, restroom facility is maintained in clean condition.** R9-8-807 A	Y	
14	**Dispenser with powdered or liquid soap is located at each sink in the sanitary facility.** R9-8-807 B	Y	
	WATER CIRCULATION REQUIREMENTS		
15	**Water circulation complies with requirements** R9-8-804 A.1	Y	
16	**Flow meter is present** R9-8-804 A.2.a	N	
17	**Vacuum cleaning system is present.** R9-8-804 A.2.b	Y	
	POSTING REQUIREMENTS		
18	**Operator has sign posted within 50 feet of bathing place with proper instructions to individuals using facility.** R9-8-806	Y	
	SEWAGE DISPOSAL, FILTER BACKWASH & WASTED WATER		
19	**Sewage, filter backwash from bathing place is properly disposed.** R9-8-809	Y	

A copy of the Arizona Administrative Code R9-8-801 through R9-8-813 is available at:

www.azsos.gov/public_services/Title_09/9-08.htm#Article_8

For information regarding Fecal Contamination Response Procedures see R9-8-810

Comments: Total alkalinity should be 60-100 ppm. Bottom of pool is to be vacuumed tomorrow. Flow meter is needed for pump system. Back flow preventer is needed for hose used to fill pool.

ALL VIOLATIONS ARE TO BE CORRECTED BY: next routine inspection

REPORT RECEIVED BY: [signature]

INSPECTED BY: Doug Walker DATE/TIME: 7-23-13

Revised 4/22/2009

PINAL COUNTY ENVIRONMENTAL HEALTH SERVICES
As Governed by
A.R.S. 36-601.01 and A.A.C. Title 9, Chapter 2, Article 1
P.O. BOX 2517; 31N. Pinal St., Bldg F
Florence, AZ 85132
(520) 866-6864
Fax (520) 866-6007

PINAL · COUNTY

SMOKE FREE

SUMMARY INSPECTION REPORT

ESTABLISHMENT NAME:	Marana Aerospace Solutions Motel
ADDRESS:	24641 Pinal Air Pk Rd
CITY, ZIP CODE:	Marana Az

INSPECTION	INSPECTION TIME:	INSPECTION PURPOSE:	Smoke Free

Based on an inspection conducted this day, the items below identify the violation(s) observed by the Department. Failure to correct may result in a Notice of Violation and Notice of Assessment of Civil Penalties.

SIGNAGE		
1A.	Lack of a sign is required under A.R.S. 36-601.01(E)(1) and (2); A.A.C. R9-2-105(A); A.A.C. R9-2-105(C). Laundry + motel office to c signs	No
1B.	Presence of a sign that does not meet the requirements of A.R.S. 36-601.01(E)(1); R9-2-105(A); A.A.C. R9-2-105(C).	No
ASHTRAYS		
2A-1.	Presence of an ashtray inside in an area where smoking is prohibited. A.R.S. 36-601.01(E)(3); A.A.C. R9-2-105(A); A.A.C. R9-2-104(A)(4).	No
2A-2.	Presence of an ashtray outside (within 20 feet of entrance) in an area where smoking is prohibited. A.R.S. 36-601.01(E)(3); A.A.C. R9-2-105(A); A.A.C. R9-2-104(A)(4).	No
PROPRIETOR PERMITTING SMOKING WHERE PROHIBITED		
	Proprietor permitting smoking in a public place, a place of employment, or within the distance specified in A.A.C. R9-2-102(A). A.R.S.36-601.01(B) and A.A.C. R9-2-104(A)(1)(except according to the exceptions listed in A.R.S. 36-601.01(B))	
3A-1.	Presence of smoking inside in an area where smoking is prohibited.	No
3A-2.	Presence of smoking outside(within 20 feet of an entrance) in an area where smoking is prohibited.	No
3A-3.	Who was smoking - Owner/Manager/Person in Charge?	No
3A-4.	Who was smoking - Customer/Visitor(s)?	No
3A-5.	Who was smoking - Employee/Worker(s)?	No
3A-6.	Who was smoking - Other?	No
3A-7.	Presence of tobacco ashes, cigarette butts and filters, or cigar stubs inside in an area where smoking is prohibited.	No
3A-8.	Presence of tobacco ashes, cigarette butts and filters, or cigar stubs outside (within 20 feet of an entrance) in an area where smoking is prohibited.	No
SMOKE DRIFTING INTO AN AREA WHERE SMOKING IS PROHIBITED		
4A.	Proprietor permitting tobacco smoke to drift into a building or facility through an entrance, a window, a ventilation system, or other means. A.A.C. R9-2-102(B); A.A.C R9-2-104(A)(2); A.A.C. R9-2-108(C); A.A.C. R9-2-108(E)(2)	No
OUTDOOR PATIOS		
5A.	Outdoor patio where smoking is permitted does not meet the requirements of A.A.C. R9-2-108.	No
COMMUNICATION / EDUCATION		
6A.	Proprietor failing to communicate to all existing and prospective employees (upon their application for employment) that smoking prohibited in places of employment. A.R.S 36-601.01(C) and A.A.C. R9-2-104(A)(5)	No
6B.	Owner, manager, operator or employee of place regulated by A.R.S. 36-601.01 failing to inform any person who is smoking in violation of A.R.S. 36-601.01 that smoking is illegal and request that the illegal smoking stop immediately. A.R.S. 36-601.01(1)	No
RETAIL TOBACCO STORES		
7A.	Enclosed public place of place of employment is not a retail store that derives the majority of its sales from tobacco products and accessories. A.R.S. 36-601.01(A)(10) and A.A.C. R9-2-107(A).	Yes
7B.	Retail tobacco store as defined by A.R.S. 36-601.01(A)(10) is not physically separated so that smoke from retail tobacco store does not infiltrate into areas where smoking is prohibited. A.R.S. 36-601.01(B)(3) and A.A.C. R9-2-107(A)	No
7C.	Proprietor of retail tobacco store where smoking is permitted is unwilling to provide or does not have an affidavit on-site containing the information required under A.A.C. R9-2-107(B) or (C). A.A.C. R9-2-107(D)(1) and A.A.C. R9-2-107(E)(1)	No
7D.	Proprietor of retail tobacco store where smoking is permitted is unwilling to provide or does not have documents on-site that enable the Department or Department's designee to determine the percent of gross income derived from the sale of tobacco products and accessories. A.A.C. R9-2-107(D)(2) and R9-2-107(E)(2)	No
MISCELLANEOUS		
8A.	Proprietor failing to permit the Department of Department's designee to conduct an inspection to determine compliance with A.R.S. 36-601.01 and A.A.C. R9-2-101 through A.A.C. R9-2-112. A.R.S. 36-601-01(G)(4)	No
8B.	Employer discharging or retaliating against an employee because the employee exercised rights afforded by A.R.S.36-601.01 and A.A.C. R9-2-112. A.R.S. 36-601.01(F)	No
	EDUCATIONAL MATERIALS PROVIDED	No
	"NO SMOKING" SIGNS PROVIDED	No
55.	Smoke Free Arizona Verification	Yes

ITEM #	DESCRIPTION OF OBSERVATION
	Describe observation of violation(s), including any corrective action(s) that have taken place or are required to take place in order to be in compliance with A.R.S. § 36-601.01 and A.A.C. R9-2-101 through R9-2-112.

Proprietor

Print Name and Title LARA N. FISK

Signature:

Pinal County Environmental Health Representative

Print Name Doug Walker

Signature:

PINAL • COUNTY
wide open opportunity

PINAL COUNTY ENVIRONMENTAL HEALTH SERVICES

NOTICE OF INSPECTION RIGHTS

Facility Inspected: Marana Aerospace Solution Permit No. _____
Address: 24641 Pinal Air Park City: Marana Zip: _____
Inspector: Doug Walker Accompanied by: Pemus

1. This inspection is conducted under the authority of Arizona Revised Statutes (A.R.S.) Title 36, Chapter 1, Article 2, § 36-136(D), Arizona Department of Health Services/Pinal County Delegation Agreement No. AGR2007-108, and Arizona Administrative Code (A.A.C.) Title 9, Chapter 8, Article 1 (Food and Drink), Title 9, Chapter 8, Article 2 (Bottled Water), Title 9, Chapter 8, Article 3 (Public Toilet Facilities), Title 9, Chapter 8, Article 4 (Children's Camps), Title 9, Chapter 8, Article 5 (Trailer Coach Parks), Title 9, Chapter 8, Article 6 (Camp Grounds), Title 9, Chapter 8, Article 7 (Public Schools), Title 9, Chapter 8, Article 8 (Public and Semipublic Swimming Pools and Bathing Places), and Title 9, Chapter 8, Article 13 (Hotels, Motels, and Tourist Courts).

2. The purpose of this inspection is to assess compliance of your establishment/facility with the above-listed administrative rules and regulations as they pertain to the issuance of a license or compliance with licensure requirements.

3. Applicable fees associated with this inspection: ☒ None ☐ Fee Amount $_____

4. An authorized on-site representative of the regulated person may accompany the County inspector on the premises, except during confidential interviews.

5. You have the right to have:
   - Copies of any original documents taken by the county during the inspection if the County is permitted by law to take the original documents;
   - A split of any samples taken during the inspection if the split of any samples would not prohibit an analysis from being conducted or render an analysis inconclusive; and
   - Copies of any analysis performed on samples taken during the inspection

6. Each person who has a conversation with the County inspector during the inspection that is tape recorded will be informed that the conversation is being tape recorded.

7. Each person interviewed will be informed that statements made by the person may be included in the inspection report.

8. Your due process rights relating to an appeal of a final decision of the County based on the results of the inspection are found at A.R.S. §§ 41-1061 to 41-1066. Your rights relating to an appeal of a final County decision are found in A.R.S. § 12-901, *et seq.* A county decision pursuant to A.R.S. § 11-1603 E and F is not an appealable county action.

9. For questions regarding the inspection or to get further information about due process rights of a regulated person relating to an appeal of a final decision based on the results of the inspection, you may contact: Environmental Health Programs Manager, 971 N. Jason Lopez Circle, PO Box 2945, Florence, Arizona 85132, Phone: (866) 960-0633, FAX: (520) 866-7066 or contact the inspector at the number provided on the inspection report.

Upon entry to the premises for this inspection, the inspector(s) presented photo identification and reviewed with me the above Notice of Inspection Rights. I have read the disclosures and am notified of my inspection and due process rights as listed. I understand that while I have the right to decline to sign this form, the Pinal County Environmental Health Services inspector(s) may proceed with the inspection.

_____
Printed name of regulated person or on-site representative of the regulated person

_____
Signature of regulated person or on-site representative of the regulated person — Date of Inspection

☐ Regulated person or on-site representative refused to sign this form
☐ Regulated person or on-site representative is not present

Doug Walker — 7-23-13
PCEHS Inspector(s) Signature — Date of Inspection

☒ Copy left with the regulated person or on-site representative of the regulated person
☐ Copy faxed, mailed, emailed to the regulated person or on-site representative of the regulated person

Need new permits!

Pinal County Environmental Health Services
As Governed by
A.A.C. Title 9, Chapter 8, Article 7
P.O. BOX 2517, 31N. Pinal St., Bldg F
Florence, AZ 85132
(520) 866-6864
Fax (520) 866-6007

PINAL • COUNTY
With open opportunity

PUBLIC AND SEMI PUBLIC BATHING PLACE

INSPECTION REPORT

Facility Name:	MARANA AEROSPACE SOLUTIONS	Classification:	Semi-Public
Address:	24641 E PINAL AIR PARK RD	City:	MARANA
Owner:		Operator:	
Permit #:	BP-12-006 Phone:	Type of Inspection:	Follow Up

Based on an inspection this day, the items marked below may identify violations in operation of facilities which must be corrected by the next inspection or by the time specified by the health authority, failure to comply with this notice may result in immediate suspension of your permit. An opportunity for an appeal will be provided if a written request is filed with the health authority within the period of time established in this notice for correction of violations.

Y = Yes N = No N/O = Not Observed N/A = Not Applicable

	TYPE OF BATHING PLACE:	Pool	Spa	Pool	Spa
	DISINFECTION LEVELS	READINGS		Compliance Status	
1	If chlorine is used as disinfectant (Pool) R9-8-803 D.1 (Spa)R9-8-803 E.3.a	0.5 ppm		N	
2	If bromine is used as disinfectant (Pool) R9-8-803 D.2 (Spa)R9-8-803 E.3.b	ppm		N/A	
	OPERATING PROCEDURES & STANDINGS				
3	pH is between 7.2 and 7.8 R9-8-803 A.2.b.a	7.8 ppm		Y	
4	Total alkalinity is 60 and 100 ppm R9-8-803 A.2.c.b	130 ppm		N	
5	Cyanuric acid level does not exceed 150 ppm. R9-8-803 C	0 ppm		Y	
6	Only Potable water is used for filling R9-8-803 A.1a			Y	
7	Main drain clearly visible from the deck. R9-8-803 A.2.d			Y	
8	Surface of the water is free from scum and floating debris R9-8-803 A.3			Y	
9	Bottom and sides free of sediment, dirt, slime and algae. R9-8-803 A.4			N	
10	Chemical disinfection level, pH, total alkalinity, and temperature of water tested at lease once daily. R9-8-803 A.5			Y	
11	Daily operating log is maintained for 12 months and available to regulatory authority or member of the public upon request. R9-8-803 A.6			Y	
12	Dry or liquid disinfectant is not being directly added to bathing place for routine disinfection. R9-8-803 B.3			Y	

	TYPE OF BATHING PLACE:	Pool	Spa
	FACILITY SANITATION	Compliance Status	
13	If present, restroom facility is maintained in clean condition R9-8-807 A	Y	
14	Dispenser with powdered or liquid soap is located at each sink in the sanitary facility. R9-8-807 B	Y	
	WATER CIRCULATION REQUIREMENTS		
15	Water Circulation complies with requirements R9-8-804 A.1	Y	
16	Flow meter is present R9-8-804 A.2.a	N	
17	Vacuum cleaning system is present. R9-8-804 A.2.b	Y	
	POSTING REQUIREMENTS		
18	Operator has sign posted within 50 feet of bathing place with proper instructions to individuals using facilities R9-8-806	Y	
	SEWAGE DISPOSAL, FILTER BACKWASH AND WASTED WATER		
19	Sewage, filter backwash from bathing place is properly disposed R9-8-809	Y	

A copy of the Arizona Administrative Code R9-8-801 through R9-8-813 is available at. www.azsos.gov/public_service/Title_09/9-08.htm#Article_8

For information regarding Fecal Contamination Response Procedures see R9-8-810

Comments:

The pool needs to have 1-3 ppm chlorine, now is low. Bottom of pool needs to be vacuumed, especially in middle of pool to remove leaves. Flow meter is needed for pump system.

ALL VIOLATIONS ARE TO BE CORRECTED BY: prior to use of pool (low chlorine level)

REPORT RECEIVED BY: [signature]

INSPECTED BY: Doug Walker **DATE/TIME:** 6/14/2013 12:46:13 PM

PINAL COUNTY ENVIRONMENTAL HEALTH SERVICES
As Governed by
A.R.S. 36-601 01 and A.A.C. Title 9, Chapter 2, Article 1
P.O. BOX 2517; 31N. Pinal St., Bldg F
Florence, AZ 85132
(520) 866-6864
Fax (520) 866-6007

SMOKE FREE

SUMMARY INSPECTION REPORT

ESTABLISHMENT NAME: Marana Aerospace Solutions
ADDRESS: 24641 E Pinal Air Park
CITY, ZIP CODE: Marana

INSPECTION | **INSPECTION TIME:** | **INSPECTION PURPOSE:** **Smoke Free**

Based on an inspection conducted this day, the items below identify the violation(s) observed by the Department. Failure to correct may result in a Notice of Violation and Notice of Assessment of Civil Penalties.

SIGNAGE		
1A.	Lack of a sign is required under A.R.S. 36-601.01(E)(1) and (2); A.A.C. R9-2-105(A); A.A.C. R9-2-105(C).	Yes
1B.	Presence of a sign that does not meet the requirements of A.R.S. 36-601.01(E)(1); R9-2-105(A); A.A.C. R9-2-105(C).	No
ASHTRAYS		
2A-1.	Presence of an ashtray inside in an area where smoking is prohibited. A.R.S. 36-601.01(E)(3); A.A.C. R9-2-105(A); A.A.C. R9-2-104(A)(4).	No
2A-2.	Presence of an ashtray outside (within 20 feet of entrance) in an area where smoking is prohibited. A.R.S. 36-601.01(E)(3); A.A.C. R9-2-105(A), A.A.C. R9-2-104(A)(4).	Yes
PROPRIETOR PERMITTING SMOKING WHERE PROHIBITED		
Proprietor permitting smoking in a public place, a place of employment, or within the distance specified in A.A.C. R9-2-102(A). A.R.S.36-601.01(B) and A.A.C. R9-2-104(A)(1)(except according to the exceptions listed in A.R.S. 36-601.01(B))		
3A-1.	Presence of smoking inside in an area where smoking is prohibited.	No
3A-2.	Presence of smoking outside(within 20 feet of an entrance) in an area where smoking is prohibited.	No
3A-3.	Who was smoking - Owner/Manager/Person in Charge?	No
3A-4.	Who was smoking - Customer/Visitor(s)?	No
3A-5.	Who was smoking - Employee/Worker(s)?	No
3A-6.	Who was smoking - Other?	No
3A-7.	Presence of tobacco ashes, cigarette butts and filters, or cigar stubs inside in an area where smoking is prohibited.	No
3A-8.	Presence of tobacco ashes, cigarette butts and filters, or cigar stubs outside (within 20 feet of an entrance) in an area where smoking is prohibited.	Yes
SMOKE DRIFTING INTO AN AREA WHERE SMOKING IS PROHIBITED		
4A.	Proprietor permitting tobacco smoke to drift into a building or facility through an entrance, a window, a ventilation system, or other means. A.A.C. R9-2-102(B); A.A.C R9-2-104(A)(2); A.A.C. R9-2-108(C); A.A.C. R9-2-108(E)(2)	No
OUTDOOR PATIOS		
5A.	Outdoor patio where smoking is permitted does not meet the requirements of A.A.C. R9-2-108.	No
COMJMUNICATION / EDUCATION		
6A.	Proprietor failing to communicate to all existing and prospective employees (upon their application for employment) that smoking prohibited in places of employment. A.R.S 36-601.01(C) and A.A.C. R9-2-104(A)(5)	No
6B.	Owner, manager, operator or employee of place regulated by A.R.S. 36-601.01 failing to inform any person who is smoking in violation of A.R.S. 36-601.01 that smoking is illegal and request that the illegal smoking stop immediately. A.R.S. 36-601.01(1)	No
RETAIL TOBACCO STORES		
7A.	Enclosed public place of place of employment is not a retail store that derives the majority of its sales from tobacco products and accessories. A.R.S. 36-601.01(A)(10) and A.A.C. R9-2-107(A).	Yes
7B.	Retail tobacco store as defined by A.R.S. 36-601.01(A)(10) is not physically separated so that smoke from retail tobacco store does not infiltrate into areas where smoking is prohibited. A.R.S. 36-601 01(B)(3) and A.A.C. R9-2-107(A)	No
7C.	Proprietor of retail tobacco store where smoking is permitted is unwilling to provide or does not have an affidavit on-site containing the information required under A.A.C. R9-2-107(B) or (C). A.A.C. R9-2-107(D)(1) and A.A.C. R9-2-107(E)(1)	No
7D.	Proprietor of retail tobacco store where smoking is permitted is unwilling to provide or does not have documents on-site that enable the Department or Department's designee to determine the percent of gross income derived from the sale of tobacco products and accessories. A.A.C. R9-2-107(D)(2) and R9-2-107(E)(2)	No
MISCELLANEOUS		
8A.	Proprietor failing to permit the Department of Department's designee to conduct an inspection to determine compliance with A.R.S. 36-601.01 and A.A.C. R9-2-101 through A.A.C. R9-2-112. A.R.S. 36-601-01(G)(4)	No
8B.	Employer discharging or retaliating against an employee because the employee exercised rights afforded by A.R.S.36-601.01 and A.A.C. R9-2-112. A.R.S. 36-601.01(F)	No

Proprietor	Pinal County Environmental Health Representative
Print Name and Title	Print Name
Signature:	Signature:

PINAL COUNTY ENVIRONMENTAL HEALTH SERVICES
As Governed by
A.R.S. 36-601.01 and A.A.C. Title 9, Chapter 2, Article 1
P.O. BOX 2517; 31N. Pinal St., Bldg F
Florence, AZ 85132
(520) 866-6864
Fax (520) 866-6007

SMOKE FREE

SUMMARY INSPECTION REPORT

ESTABLISHMENT NAME:

ADDRESS:

CITY, ZIP CODE:

INSPECTION | **INSPECTION TIME:** | **INSPECTION PURPOSE:** | **Smoke Free**

	ENDUCATIONAL MATERIALS PROVIDED	No
	"NO SMOKING" SIGNS PROVIDED	Yes
55.	Smoke Free Arizona Verification	Yes

ITEM #	DESCRIPTION OF OBSERVATION
	Describe observation of violation(s), including any corrective action(s) that have taken place or are required to take place in order to be in compliance with A.R.S. § 36-601.01 and A.A.C. R9-2-101 through R9-2-112.
1A.	3 small SF signs were provided for the motel office, and 2 laundry room entrances which all lacked signage.
2A-2.	A 5 gallon bucked by the entrance to the motel office had a few cigarette butts in it. It was moved from the area. There was notification not to smoke in the area.

Proprietor

Print Name and Title

Signature:

Pinal County Environmental Health Representative

Print Name Vern Scarbrough

Signature:

PINAL • COUNTY
wide open opportunity

PINAL COUNTY ENVIRONMENTAL HEALTH SERVICES

NOTICE OF INSPECTION RIGHTS

Smoke free

Facility Inspected: Marana aerospace Solutions pool + Permit No. _____
Address: 24641 E Pinal Air Park Rd City: Marana Zip: _____
Inspector: Doug Walker Accompanied by: Vern

1. This inspection is conducted under the authority of Arizona Revised Statutes (A.R.S.) Title 36, Chapter 1, Article 2, § 36-136(D), Arizona Department of Health Services/Pinal County Delegation Agreement No. AGR2007-108, and Arizona Administrative Code (A.A.C.) Title 9, Chapter 8, Article 1 (Food and Drink), Title 9, Chapter 8, Article 2 (Bottled Water), Title 9, Chapter 8, Article 3 (Public Toilet Facilities), Title 9, Chapter 8, Article 4 (Children's Camps), Title 9, Chapter 8, Article 5 (Trailer Coach Parks), Title 9, Chapter 8, Article 6 (Camp Grounds), Title 9, Chapter 8, Article 7 (Public Schools), Title 9, Chapter 8, Article 8 (Public and Semipublic Swimming Pools and Bathing Places), and Title 9, Chapter 8, Article 13 (Hotels, Motels, and Tourist Courts).

2. The purpose of this inspection is to assess compliance of your establishment/facility with the above-listed administrative rules and regulations as they pertain to the issuance of a license or compliance with licensure requirements.

3. Applicable fees associated with this inspection: ☒ None ☐ Fee Amount $_____

4. An authorized on-site representative of the regulated person may accompany the County inspector on the premises, except during confidential interviews.

5. You have the right to have:
   - Copies of any original documents taken by the county during the inspection if the County is permitted by law to take the original documents;
   - A split of any samples taken during the inspection if the split of any samples would not prohibit an analysis from being conducted or render an analysis inconclusive; and
   - Copies of any analysis performed on samples taken during the inspection

6. Each person who has a conversation with the County inspector during the inspection that is tape recorded will be informed that the conversation is being tape recorded.

7. Each person interviewed will be informed that statements made by the person may be included in the inspection report.

8. Your due process rights relating to an appeal of a final decision of the County based on the results of the inspection are found at A.R.S. §§ 41-1061 to 41-1066. Your rights relating to an appeal of a final County decision are found in A.R.S. § 12-901, *et seq.* A county decision pursuant to A.R.S. § 11-1603 E and F is not an appealable county action.

9. For questions regarding the inspection or to get further information about due process rights of a regulated person relating to an appeal of a final decision based on the results of the inspection, you may contact: Environmental Health Programs Manager, 31 N. Pinal St., Bldg F (PO Box 2517), Florence, Arizona 85132, Phone: (520) 866-6807, FAX: (520) 866-6007 or contact the inspector at the number provided on the inspection report.

Upon entry to the premises for this inspection, the inspector(s) presented photo identification and reviewed with me the above Notice of Inspection Rights. I have read the disclosures and am notified of my inspection and due process rights as listed. I understand that while I have the right to decline to sign this form, the Pinal County Environmental Health Services inspector(s) may proceed with the inspection.

LARA N. FISK
Printed name of regulated person or on-site representative of the regulated person

Signature of regulated person or on-site representative of the regulated person — Date of Inspection: 6/14/13

☐ Regulated person or on-site representative refused to sign this form
☐ Regulated person or on-site representative is not present

PCEHS Inspector(s) Signature — Date of Inspection: 6-14-13

☒ Copy left with the regulated person or on-site representative of the regulated person
☐ Copy faxed, mailed, emailed to the regulated person or on-site representative of the regulated person _____

Pinal County Environmental Health Services
As Governed by
A.A.C. Title 9, Chapter 8, Article 7
P.O. BOX 2517, 31N. Pinal St., Bldg F
Florence, AZ 85132
(520) 866-6864
Fax (520) 866-6007

PINAL • COUNTY
Wide open opportunity

PUBLIC AND SEMI PUBLIC BATHING PLACE

INSPECTION REPORT

Facility Name:	MARANA AEROSPACE SOLUTIONS	Classification:	Semi-Public
Address:	24641 E PINAL AIR PARK RD	City:	MARANA
Owner:		Operator:	
Permit #:	BP-12-006	Phone:	
Type of Inspection:	Routine		

Based on an inspection this day, the items marked below may identify violations in operation of facilities which must be corrected by the next inspection or by the time specified by the health authority, failure to comply with this notice may result in immediate suspension of your permit. An opportunity for an appeal will be provided if a written request is filed with the health authority within the period of time established in this notice for correction of violations.

Y = Yes N = No N/O = Not Observed N/A = Not Applicable

	TYPE OF BATHING PLACE:	Pool	Spa	Pool	Spa
	DISINFECTION LEVELS	READINGS		Compliance Status	
1	If chlorine is used as disinfectant (Pool) R9-8-803 D.1 (Spa)R9-8-803 E.3.a	2.0 ppm		Y	
2	If bromine is used as disinfectant (Pool) R9-8-803 D.2 (Spa)R9-8-803 E.3.b	ppm		N/A	
	OPERATING PROCEDURES & STANDINGS				
3	pH is between 7.2 and 7.8 R9-8-803 A.2.b.a	7.8 ppm		Y	
4	Total alkalinity is 60 and 100 ppm R9-8-803 A.2.c.b	140 ppm		N	
5	Cyanuric acid level does not exceed 150 ppm. R9-8-803 C	10 ppm		Y	
6	Only Potable water is used for filling R9-8-803 A.1a			Y	
7	Main drain clearly visible from the deck. R9-8-803 A.2.d			Y	
8	Surface of the water is free from scum and floating debris R9-8-803 A.3			Y	
9	Bottom and sides free of sediment, dirt, slime and algae. R9-8-803 A.4			N	
10	Chemical disinfection level, pH, total alkalinity, and temperature of water tested at lease once daily. R9-8-803 A.5			Y	
11	Daily operating log is maintained for 12 months and available to regulatory authority or member of the public upon request. R9-8-803 A.6			Y	
12	Dry or liquid disinfectant is not being directly added to bathing place for routine disinfection. R9-8-803 B.3			N	

	TYPE OF BATHING PLACE:	Pool	Sp
	FACILITY SANITATION	Compliance Status	
13	If present, restroom facility is maintained in clean condition R9-8-807 A	Y	
14	Dispenser with powdered or liquid soap is located at each sink in the sanitary facility. R9-8-807 B	Y	
	WATER CIRCULATION REQUIREMENTS		
15	Water Circulation complies with requirements R9-8-804 A.1	Y	
16	Flow meter is present R9-8-804 A.2.a	N	
17	Vacuum cleaning system is present. R9-8-804 A.2.b	Y	
	POSTING REQUIREMENTS		
18	Operator has sign posted within 50 feet of bathing place with proper instructions to individuals using facilities R9-8-806	Y	
	SEWAGE DISPOSAL, FILTER BACKWASH AND WASTE WATER		
19	Sewage, filter backwash from bathing place is properly disposed R9-8-809	Y	

A copy of the Arizona Administrative Code R9-8-801 through R9-8-813 is available at: www.azsos.gov/public_service/Title_09/9-08.htm#Article_8

For information regarding Fecal Contamination Response Procedures see R9-810

Comments:

A dust storm took the roof off the pump room and restrooms building. The pool should be closed until chlorinator can be in operation. Now the pool is chlorinated by adding tablets to a 5 gallon bucked in the pool. Algae needs to be cleaned off the bottom. Flow meter is needed for the pump system to show gallons /minute flow rate. Logs need to be resumed when the poo is opened after the chlorinator is repaired.

ALL VIOLATIONS ARE TO BE CORRECTED BY: prior to use of pool (chlorinator needs repair)

REPORT RECEIVED BY:

INSPECTED BY: Doug Walker **DATE/TIME:** 5/30/2013 4:30:32 PM

PINAL • COUNTY
wide open opportunity

PINAL COUNTY ENVIRONMENTAL HEALTH SERVICES

NOTICE OF INSPECTION RIGHTS

Facility Inspected: Marana Aerospace Solutions Pool Permit No. _____
Address: 24641 Pinal Ranch Rd City: Marana Zip: 85653
Inspector or Regulator: Doug Walker Accompanied by: Sam Soria

1. This inspection is conducted under the authority of Arizona Revised Statutes (A.R.S.) Title 49, Chapter 1, Article 1, §§ 49-106 and 49-107, Arizona Department of Environmental Quality/Pinal County Delegation Agreement No. 06-0028, and Arizona Administrative Code (A.A.C.) Title 18, Chapter 9, Articles 1 and 3 (Aquifer Protection Permits); Title 18, Chapter 13, Article 3 (Refuse and Other Objectionable Wastes); Title 18, Chapter 13, Article 11 (Collection, Transportation, and Disposal of Human Excreta); Pinal County Sanitary Code, Chapter 10 (On-site Wastewater Treatment Facilities).

2. The purpose of this inspection is to assess compliance of your facility with the above-listed administrative rules and regulations as they pertain to the issuance of a license or compliance with licensure requirements.

3. Applicable fees associated with this inspection: ☒ None ☐ Fee Amount $_____

4. An authorized on-site representative of the regulated person may accompany the County inspector on the premises, except during confidential interviews.

5. You have the right to have:
   - Copies of any original documents taken by the county during the inspection if the County is permitted by law to take the original documents;
   - A split of any samples taken during the inspection if the split of any samples would not prohibit an analysis from being conducted or render an analysis inconclusive; and
   - Copies of any analysis performed on samples taken during the inspection

6. Each person who has a conversation with the County inspector during the inspection that is tape recorded will be informed that the conversation is being tape recorded.

7. Each person interviewed will be informed that statements made by the person may be included in the inspection report.

8. Your due process rights relating to an appeal of a final decision of a County based on the results of the inspection are found at A.R.S. §§ 41-1061 to 41-1066 and Pinal County Sanitary Code, Chapter 10, Section 10.09. Your rights relating to an appeal of a final County decision are found in A.R.S. § 12-901, *et seq*. A county decision pursuant to A.R.S. § 11-1603 E and F is not an appealable county action.

9. For questions regarding the inspection or to get further information about due process rights of a regulated person relating to an appeal of a final decision based on the results of the inspection, you may contact: Atul Shah, Environmental Engineering Manager, 31 N. Pinal St., Bldg F (PO Box 2517), Florence, Arizona 85132, Phone: (520) 866-6562, FAX: (520) 866-6007 or contact the inspector at the number provided on the inspection report.

Upon entry to the premises for this inspection, the inspector(s) presented photo identification and reviewed with me the above Notice of Inspection Rights. I have read the disclosures and am notified of my inspection and due process rights as listed. I understand that while I have the right to decline to sign this form, the Pinal County Environmental Health Services inspectors(s) may proceed with the inspection.

Sam Soria
Printed name of regulated person or on-site representative of the regulated person

Signature of regulated person or on-site representative of the regulated person — Date of Inspection

☐ Regulated person or on-site representative refused to sign this form
☐ Regulated person or on-site representative is not present

D Walker — 5-30-13
PCEHS Inspector(s) or Regulator(s) Signature — Date of Inspection

☑ Copy left with the regulated person or on-site representative of the regulated person
☐ Copy faxed, mailed, emailed to the regulated person or on-site representative of the regulated person _____

Pinal County Environmental Health Services
As Governed by
A.A.C. Title 9, Chapter 8, Article 7
P.O BOX 2517, 31N. Pinal St., Bldg F
Florence, AZ 85132
(520) 866-6864
Fax (520) 866-6007

PINAL COUNTY

PUBLIC AND SEMI PUBLIC BATHING PLACE

INSPECTION REPORT

Facility Name:	MARANA AEROSPACE SOLUTIONS	Classification:	Semi-Public
Address:	24641 E PINAL AIR PARK RD	City:	MARANA
Owner:		Operator:	
Permit #:	BP-12-006 Phone:	Type of Inspection:	Routine

Based on an inspection this day, the items marked below may identify violations in operation of facilities which must be corrected by the next inspection or by the time specified by the health authority, failure to comply with this notice may result in immediate suspension of your permit. An opportunity for an appeal will be provided if a written request is filed with the health authority within the period of time established in this notice for correction of violations.

Y = Yes N = No N/O = Not Observed N/A = Not Applicable

	TYPE OF BATHING PLACE:	Pool	Spa	Pool	Spa
	DISINFECTION LEVELS	READINGS		Compliance Status	
1	If chlorine is used as disinfectant (Pool) R9-8-803 D.1 (Spa)R9-8-803 E.3.a	1.0 ppm		Y	
2	If bromine is used as disinfectant (Pool) R9-8-803 D.2 (Spa)R9-8-803 E.3.b	ppm		N/A	
	OPERATING PROCEDURES & STANDINGS				
3	pH is between 7.2 and 7.8 R9-8-803 A.2.b.a	7.8 ppm		Y	
4	Total alkalinity is 60 and 100 ppm R9-8-803 A.2.c.b	120 ppm		N	
5	Cyanuric acid level does not exceed 150 ppm. R9-8-803 C	30 ppm		Y	
6	Only Potable water is used for filling R9-8-803 A.1a			Y	
7	Main drain clearly visible from the deck. R9-8-803 A.2.d			Y	
8	Surface of the water is free from scum and floating debris R9-8-803 A.3			Y	
9	Bottom and sides free of sediment, dirt, slime and algae. R9-8-803 A.4			N	
10	Chemical disinfection level, pH, total alkalinity, and temperature of water tested at lease once daily. R9-8-803 A.5			N/O	
11	Daily operating log is maintained for 12 months and available to regulatory authority or member of the public upon request. R9-8-803 A.6			N/O	
12	Dry or liquid disinfectant is not being directly added to bathing place for routine disinfection. R9-8-803 B.3			Y	

	TYPE OF BATHING PLACE:	Pool	Spa
	FACILITY SANITATION	Compliance Status	
13	If present, restroom facility is maintained in clean condition R9-8-807 A	Y	
14	Dispenser with powdered or liquid soap is located at each sink in the sanitary facility. R9-8-807 B	Y	
	WATER CIRCULATION REQUIREMENTS		
15	Water Circulation complies with requirements R9-8-804 A.1	Y	
16	Flow meter is present R9-8-804 A.2.a	N/O	
17	Vacuum cleaning system is present. R9-8-804 A.2 b	Y	
	POSTING REQUIREMENTS		
18	Operator has sign posted within 50 feet of bathing place with proper instructions to individuals using facilities R9-8-806	Y	
	SEWAGE DISPOSAL, FILTER BACKWASH AND WASTED WATER		
19	Sewage, filter backwash from bathing place is properly disposed R9-8-809	Y	

A copy of the Arizona Administrative Code R9-8-801 through R9-8-813 is available at. www.azsos.gov/public_service/Title_09/9-08.htm#Article_8

For information regarding Fecal Contamination Response Procedures see R9-8-810

Comments:

Pool bottom looks better, some leaves and gravel are at the shallow end. Total alkalinity should be lowered to 60-100 ppm.

ALL VIOLATIONS ARE TO BE CORRECTED BY: next routine inspection

REPORT RECEIVED BY: [signature] 09/05/12

INSPECTED BY: Doug Walker **DATE/TIME:** 9/5/2012 2:07:26 PM

PINAL • COUNTY
wide open opportunity

PINAL COUNTY ENVIRONMENTAL HEALTH SERVICES

NOTICE OF INSPECTION RIGHTS

Facility Inspected: Marana Aerospace Solutions Permit No. BP-12-006
Address: 24641 E Pinal Elm Park Rd City: Marana Zip: _____
Inspector: Doug Walker Accompanied by: _____

1. This inspection is conducted under the authority of Arizona Revised Statutes (A.R.S.) Title 36, Chapter 1, Article 2, § 36-136(D), Arizona Department of Health Services/Pinal County Delegation Agreement No. AGR2007-108, and Arizona Administrative Code (A.A.C.) Title 9, Chapter 8, Article 1 (Food and Drink), Title 9, Chapter 8, Article 2 (Bottled Water), Title 9, Chapter 8, Article 3 (Public Toilet Facilities), Title 9, Chapter 8, Article 4 (Children's Camps), Title 9, Chapter 8, Article 5 (Trailer Coach Parks), Title 9, Chapter 8, Article 6 (Camp Grounds), Title 9, Chapter 8, Article 7 (Public Schools), Title 9, Chapter 8, Article 8 (Public and Semipublic Swimming Pools and Bathing Places), and Title 9, Chapter 8, Article 13 (Hotels, Motels, and Tourist Courts).

2. The purpose of this inspection is to assess compliance of your establishment/facility with the above-listed administrative rules and regulations as they pertain to the issuance of a license or compliance with licensure requirements.

3. Applicable fees associated with this inspection: ☒ None ☐ Fee Amount $_____

4. An authorized on-site representative of the regulated person may accompany the County inspector on the premises, except during confidential interviews.

5. You have the right to have:
   - Copies of any original documents taken by the county during the inspection if the County is permitted by law to take the original documents;
   - A split of any samples taken during the inspection if the split of any samples would not prohibit an analysis from being conducted or render an analysis inconclusive; and
   - Copies of any analysis performed on samples taken during the inspection

6. Each person who has a conversation with the County inspector during the inspection that is tape recorded will be informed that the conversation is being tape recorded.

7. Each person interviewed will be informed that statements made by the person may be included in the inspection report.

8. Your due process rights relating to an appeal of a final decision of the County based on the results of the inspection are found at A.R.S. §§ 41-1061 to 41-1066. Your rights relating to an appeal of a final County decision are found in A.R.S. § 12-901, *et seq.* A county decision pursuant to A.R.S. § 11-1603 E and F is not an appealable county action.

9. For questions regarding the inspection or to get further information about due process rights of a regulated person relating to an appeal of a final decision based on the results of the inspection, you may contact: Environmental Health Programs Manager, 31 N. Pinal St., Bldg F (PO Box 2517), Florence, Arizona 85132, Phone: (520) 866-6807, FAX: (520) 866-6007 or contact the inspector at the number provided on the inspection report.

Upon entry to the premises for this inspection, the inspector(s) presented photo identification and reviewed with me the above Notice of Inspection Rights. I have read the disclosures and am notified of my inspection and due process rights as listed. I understand that while I have the right to decline to sign this form, the Pinal County Environmental Health Services inspector(s) may proceed with the inspection.

NORMA M. LOPEZ
Printed name of regulated person or on-site representative of the regulated person

Signature of regulated person or on-site representative of the regulated person — Date of Inspection

☐ Regulated person or on-site representative refused to sign this form
☐ Regulated person or on-site representative is not present

PCEHS Inspector(s) Signature — 9-5-12 Date of Inspection

☒ Copy left with the regulated person or on-site representative of the regulated person
☐ Copy faxed, mailed, emailed to the regulated person or on-site representative of the regulated person _____

Pinal County Enviromental Health Services
As Governed by
A.A.C. Title 9, Chapter 8, Article 8
P.O. Box 2517; 31 N. Pinal St., Bldg F
Florence, AZ 85232
(520) 866-6864
Fax (520) 866-6007

PINAL • COUNTY
Wide open opportunity

PUBLIC AND SEMI PUBLIC BATHING PLACE

INSPECTION REPORT

Facility Name:	MARANA AEROSPACE SOLUTIONS	Classification:	Semi-Public
Address:	24641 E PINAL AIR PARK RD	City:	MARANA
Owner:	Phone #:	Operator:	Phone #:
Permit #:	BP-12-006	Type of Inspection:	Routine

Based on an inspection this day, the items marked below may identify violations in operation of facilities which must be corrected by the next inspection or by the time specified by the health authority, failure to comply with this notice may result in immediate suspension of your permit. An opportunity for an appeal will be provided if a written request is filed with the health authority within the period of time established in this notice for correction of violations.

Y = Yes N = No N/O = Not Observed N/A = Not Applicable

TYPE OF BATHING PLACE: POOL

	DISINFECTION LEVELS	READINGS		Compliance Status	
1	If chlorine is used as disinfectant (Pool) R9-8-803 D.1 (Spa) R9-8-803 E.3.a	3.0 ppm	ppm	Y	
2	If bromine is used as disinfectant (Pool) R9-8-803 D.2 (Spa) R9-8-803 E.3.b	0 ppm	ppm	N/A	
	OPERATING PROCEDURES & STANDARDS				
3	pH is between 7.2 and 7.8 R9-8-803 A.2.b	7.8		Y	
4	Total alkalinity is 60 and 100 ppm R9-8-803 A.2.c	90 ppm	ppm	Y	
5	Cyanuric acid level does not exceed 150ppm. R9-8-803 C	10 ppm	ppm	Y	
6	Only potable water is used for filling. R9-8-803 A.1			Y	
7	Main drain clearly visible from deck. R9-8-803 A.2.d			Y	
8	Surface of the water is free from scum and floating debris. R9-8-803 A.3			Y	
9	Bottom and sides free of sediment, dirt, slime and algae. R9-8-803 A.4			N	
10	Chemical disinfectant level, pH, total alkalinity, and temperature of water tested at least once daily. R9-8-803 A.5			N/O	
11	Daily operating log is maintained for 12 months and available to regulatory authority or member of the public upon request. R9-8-803 A.6			N/O	
12	Dry or liquid disinfectant is not being directly added to bathing place for routine disinfection. R9-8-803 B.3			Y	

TYPE OF BATHING PLACE: POOL

	FACILITY SANITATION	Compliance Status	
13	If present, restroom facility is maintained in clean condition. R9-8-807 A	Y	
14	Dispenser with powdered or liquid soap is located at each sink in the sanitary facility. R9-8-807 B	Y	
	WATER CIRCULATION REQUIREMENTS		
15	Water circulation complies with requirements. R9-8-804 A.1	N	
16	Flow meter is present. R9-8-804 A.2.a	N/O	
17	Vacuum cleaning system is present R9-8-804 A.2.b	Y	
	POSTING REQUIREMENTS		
18	Operator has sign posted within 50 feet of bathing place with proper instructions to individuals using facility. R9-8-806	Y	
	SEWAGE DISPOSAL, FILETER BACKWASH AND WASTED WATER		
19	Sewage, filter backwash from bathing place is properly disposed. R9-8-809	Y	

A copy of the Arizona Administrative Code R9-8-801 through R9-8-813 is available at: www.azsos.gov/public_services/Title_09/9-08.htm#Article_8

For information regarding Fecal Contamination Response Procedures see R9-8-810

Comments:

Pool bottom and sides need to be cleaned to remove dirt. Water level needs to be about 1" higher for scum gutter to work to remove surface debris. Be sure logs are kept daily. Water chemistry meets minimum standards.

ALL VIOLATIONS ARE TO BE CORRECTED BY: next routine inspection

REPORT RECEIVED BY:

INSPECTED BY: Doug Walker **DATE:** 2012-07-19

PINAL • COUNTY
wide open opportunity

PINAL COUNTY ENVIRONMENTAL HEALTH SERVICES

NOTICE OF INSPECTION RIGHTS

Facility Inspected: Marana Aerospace Solutions Permit No. _____
Address: 24641 Pinal Air Park Rd City: Marana Zip: 85653-9501
Inspector: Doug Walker Accompanied by: _____

1. This inspection is conducted under the authority of Arizona Revised Statutes (A.R.S.) Title 36, Chapter 1, Article 2, § 36-136(D), Arizona Department of Health Services/Pinal County Delegation Agreement No. AGR2007-108, and Arizona Administrative Code (A.A.C.) Title 9, Chapter 8, Article 1 (Food and Drink), Title 9, Chapter 8, Article 2 (Bottled Water), Title 9, Chapter 8, Article 3 (Public Toilet Facilities), Title 9, Chapter 8, Article 4 (Children's Camps), Title 9, Chapter 8, Article 5 (Trailer Coach Parks), Title 9, Chapter 8, Article 6 (Camp Grounds), Title 9, Chapter 8, Article 7 (Public Schools), Title 9, Chapter 8, Article 8 (Public and Semipublic Swimming Pools and Bathing Places), and Title 9, Chapter 8, Article 13 (Hotels, Motels, and Tourist Courts).

2. The purpose of this inspection is to assess compliance of your establishment/facility with the above-listed administrative rules and regulations as they pertain to the issuance of a license or compliance with licensure requirements.

3. Applicable fees associated with this inspection: ☒ None ☐ Fee Amount $_____

4. An authorized on-site representative of the regulated person may accompany the County inspector on the premises, except during confidential interviews.

5. You have the right to have:
   - Copies of any original documents taken by the county during the inspection if the County is permitted by law to take the original documents;
   - A split of any samples taken during the inspection if the split of any samples would not prohibit an analysis from being conducted or render an analysis inconclusive; and
   - Copies of any analysis performed on samples taken during the inspection

6. Each person who has a conversation with the County inspector during the inspection that is tape recorded will be informed that the conversation is being tape recorded.

7. Each person interviewed will be informed that statements made by the person may be included in the inspection report.

8. Your due process rights relating to an appeal of a final decision of the County based on the results of the inspection are found at A.R.S. §§ 41-1061 to 41-1066. Your rights relating to an appeal of a final County decision are found in A.R.S. § 12-901, *et seq*. A county decision pursuant to A.R.S. § 11-1603 E and F is not an appealable county action.

9. For questions regarding the inspection or to get further information about due process rights of a regulated person relating to an appeal of a final decision based on the results of the inspection, you may contact: Environmental Health Programs Manager, 31 N. Pinal St., Bldg F (PO Box 2517), Florence, Arizona 85132, Phone: (520) 866-6807, FAX: (520) 866-6007 or contact the inspector at the number provided on the inspection report.

Upon entry to the premises for this inspection, the inspector(s) presented photo identification and reviewed with me the above Notice of Inspection Rights. I have read the disclosures and am notified of my inspection and due process rights as listed. I understand that while I have the right to decline to sign this form, the Pinal County Environmental Health Services inspector(s) may proceed with the inspection.

Mike Stile
Printed name of regulated person or on-site representative of the regulated person

Signature of regulated person or on-site representative of the regulated person — Date of Inspection: 7-19-12

☐ Regulated person or on-site representative refused to sign this form
☐ Regulated person or on-site representative is not present

PCEHS Inspector(s) Signature — Date of Inspection: 7-19-12

☒ Copy left with the regulated person or on-site representative of the regulated person
☐ Copy faxed, mailed, emailed to the regulated person or on-site representative of the regulated person _____